


ECS-2M

USER'S MANUAL



ECS 2M

Although the manufacturer has made every effort to ensure the accuracy of the information contained herein, this document is subject to change without notice due to ongoing product development.

WARNINGS AND PRECAUTIONS

Equipment, probe failure, blown fuses and/or tripped breakers may prove harmful to the contents of the building. Therefore it is strongly recommended to install backup devices and alarm or warning devices. Spare equipment should also be available at the owner's site. Equipment manufactured by the manufacturer is protected against normal line surges. High surges caused by thunder storms or power supply equipment may damage this equipment. For added security against line voltage surges, it is recommended that surge and noise suppression devices be installed at the electrical distribution panel. Use of shielded cable for probes is recommended for protection against lightning. These devices are available from most electrical supply distributors.

RECOMMENDATIONS

The manufacturer recommends that all installation procedures described herein be performed by a qualified electrician or installation technician. Furthermore the manufacturer recommends to test all the functions and equipment connected to the ECS, including the alarm system and backup devices, after installation, after modifications, and once a month after that.

Fuse verification and replacement, as well as the proper setting of control values, shall be the responsibility of the owner of this equipment.

TABLE OF CONTENTS

CHAPTER 1 - INTRODUCTION

1.	General	5
1.1	Description	5
	Definition of terms	7

CHAPTER 2 - INSTALLATION

2.1	Unpacking	9
2.2	Mounting	10
2.3	Switch Settings.....	10
2.3.1	Line Voltage Selector Switch	10
2.3.2	Software Settings Switch	11
2.4	Connection Procedure	11
2.4.1	Input Power	11
2.4.1.1	115 VAC.....	11
2.4.1.2	230 VAC.....	12
2.4.2	Fan 1	12
2.4.4	Fan 2/ Heater	12
2.5	Temperature/Humidity Probes	12
2.5.1	Single Temperature Probe	13
2.5.2	Averaging	13
2.5.3	Humidity Probe.....	13
2.6	Alarm	13
2.7	Powering Up.....	14

CHAPTER 3 - USER'S GUIDE

LED Status Window	21
Control Dials.....	21

PRIMARY FUNCTIONS

Main Set Point Temperature	23
Fan 1 Modulation Band	24
Fan 1 Minimum Speed	25
Fan 1 Duty Cycle.....	26
Heater/Fan 2 Relative Set Point.....	27

CONTENTS CONTINUED...

Reduction per Day	28
Record Low Temperature 2	9
Record High Temperature	30
Room Temperature Display	31

SECONDARY FUNCTIONS

Relative Humidity Set Point	32
Fan 1 Motor	33
Fan 1 Minimum Humidity Speed	34
Fan 1 Period	35
Heater/Fan 2 Hysteresis	36
Minimum Ramping	37
Low Temperature Alarm	38
High Temperature Alarm	39
Relative Humidity Display	40

APPENDIX

Motor Compatibility Table	43
Troubleshooting	44
Specification	45
Record Form	46

1. GENERAL

This document provides a description of the ECS-2M control panel. It is organized as follows:

- Introduction
- Installation
- User's Guide
- Appendix

1.1 DESCRIPTION

Congratulations on the purchase of your ECS-2M environmental control system. The ECS-M product line provides you with full control over temperature, humidity, air flow and heat, resulting in a comfortable environment for your livestock.

The ECS-M product line offers a number of added features over existing ECS controls such as:

- Compatible with DIP-1.
- Hi/Lo temperature indication.
- Automatic temperature reduction (ramping).
- Adaptable variable speed outputs for a wide selection of fan model types.
- Humidity probe.
- Full torque fan start preventing motor damage.

The ECS-2M provides microprocessor control over a two stage output.

The first stage controls a variable speed fan which can operate at a continuous low speed to ensure good quality of air when room temperature is below the main set point. In addition, the first stage may be programmed to cycle on and off. When room temperature rises above the main set point, the fan accelerates to increase the air flow.

DESCRIPTION CONTINUED...

The second stage controls either a heater for colder climates, or a second fan where further cooling is required.

The ECS-2M provides you with full control of two stages via the use of an easy to follow display panel. All programmable features can be customized to meet your requirements. The ECS-2M keeps you constantly informed by displaying the status of all of its outputs as well as the room temperature. With an optional humidity probe, the ECS-2M displays current humidity levels.

Safety of livestock is ensured by the continuous control of climate and timely alarm notification should environmental conditions exceed alarm set points. Further security may be obtained by connecting all ECS series controls in a network configuration to a computer via the use of an optional RCM-40 remote monitoring unit . This provides remote control monitoring of each room. All control panel variable outputs are fused, and all programmable settings are maintained whether or not the ECS-2M is powered.

The ECS-2M provides an automatic constant temperature reduction (ramping) feature for your maturing livestock. A built in low temperature safety factor prevents temperatures from reaching dangerous limits.

With the ECS-2M in control of your climate, you are assured of optimal living conditions for your livestock.

DEFINITION OF TERMS

MAIN SET POINT

The desired room temperature. Other temperature settings on the ECS-2M are relative to the main set point temperature.

RELATIVE TEMPERATURE

A value added to, or subtracted from the main set point which results in a new temperature at which a desired action starts or stops.

ROOM TEMPERATURE

The actual temperature of a closed area.

ROOM HUMIDITY

The actual humidity level of a closed area.

MINIMUM FAN SPEED

The desired minimum speed for variable speed fans.

RAMPING

An automatic daily reduction in the main set point and all temperature settings relative to this.

HYSTERESIS

Range of temperature where two conditions are possible. The output depends on whether the temperature was increasing or decreasing when it enters that range.

ECS 2M

CHAPTER 2 - INSTALLATION

Chapter 2 describes the installation of the ECS-2M control panel.

The manufacturer recommends that the following installation instructions be adhered to as closely as possible, and all work be performed by a certified electrician. Failure to do so may void the warranty!

2.1 UNPACKING

Unpack the ECS-2M and inspect contents for damage. Should the contents appear to be damaged, contact your local distributor for material return procedures.

The package should contain the following standard items:

- 1 ECS-2M control .
- 1 Installed temperature probe (model number 2004-1K).
- 2 Cable fasteners or fuses.
- 1 User manual.

The following optional items may be added:

- 3 additional temperature probes for temperature averaging,
- 1 humidity probe. The ECS-2M requires the RHT-1 humidity probe for maximum accuracy of monitoring and control of humidity levels.

2.2 MOUNTING

To limit the unit's exposure to noxious gases install it in a hallway.

Make sure the unit is mounted right side up, with the cable entry holes facing down.

The ECS-2M will operate in a temperature range of 32°F - 120 °F (0 °C - 50 °C).

* It is prohibited to use overhead cables outside the building.

Use a screwdriver to remove the faceplate and the plate on the power compartment.

Mounting hardware is not included with the unit.

Once both faceplates are off, install the mounting screw on the wall and install the unit on it. Use two more screws to secure the ECS-2 M in place using the bottom mounting holes.

2.3 SWITCH SETTINGS

The ECS-2M is configured for a variety of options via two switches as follows:

2.3.1 - Line Voltage Selector Switch

This switch is located on the surface of the main (bottom) board and adapts the control panel for 115 VAC or 230 VAC line voltage.





230V
115V

Refer to Figures 1, 2, and 3.

CHAPTER 2 - INSTALLATION

2.3.2 - Software Settings Switch

This switch is located behind the control panel faceplate and adjusts the following options.

OFF ON		OFF	ON
	1	Fahrenheit	Celsius
	2	Settings locked	Setting unlocked
	3	Stage 2 = Heat	Stage 2 = Fan
	4	Not used	Relative Humidity

- Switch 1 Selects between a Fahrenheit or Celsius display on the front panel.
- Switch 2 Locks/unlocks user settings. All settings except for main set point, record low, and record high are locked while this switch is off.
- Switch 3 Selects between a Heater or Fan control on Stage two of the control panel.
- Switch 4 To connect a humidity probe, DIP switch #4 must be ON.

2.4 CONNECTION PROCEDURE

For the connection procedures which follow refer to Figures 1 to 3.

2.4.1 - Input power

Use a screwdriver to remove cable knock-outs for the installation of cabling to the control panel.

2.4.1.1 - 115 VAC

Make sure that the line voltage selector switch is set to 115 VAC. Connect the power cable to terminals 5 and 6 on the main (bottom) board, connect the ground wire to terminal 7 on the main board .

Do not apply power to the control panel until all connections have been completed!

ECS 2M

2.4.1.2 - 230 VAC

Assure that the line voltage selector switch is set to 230 VAC. Connect the power cable to terminals 5 and 6 on the main (bottom) board, connect the ground wire to terminal 7 on the main board.

2.4.2 - Fan 1 (terminals 3 and 4)

Stage 1 of the ECS-2M controls the operation of the primary fan. Connect the two leads from Fan 1 to terminals 3 and 4 on the main (bottom) board.

2.4.3 - Fan 2/Heater (terminals 1 and 2)

Stage 2 of the ECS-2M provides a dry contact closure which controls the operation of a second fixed speed fan or a heater. This contact closure is voltage rated to 230 VAC. The current rating of the dry contact is 10 Amps (resistive) for a heater and 6 Amps (inductive) for a fan. Set the software settings DIP switch behind of the control panel faceplate to ON for a fan or OFF for a heater.

Connect the heater or Fan 2 to terminals 1 and 2 on the main (bottom) board.

2.5 TEMPERATURE / HUMIDITY PROBES

Temperature and humidity probes use a “Class 2” low voltage circuit. These cables can extend up to a distance of 500 feet (150 meters). Single probe temperature and humidity connections are illustrated in Figure 4, while temperature probe averaging connections are illustrated in Figure 5.

CHAPTER 2 - INSTALLATION

Use shielded cabling for probes . Connect the shields to “SHLD” terminal. Failure to do so may result in inaccurate readings!

2.5.1 Single Temperature Probe

Install a single temperature probe in an area that best reflects the overall temperature of the room. Connect the two leads and the shield of the temperature probe to the control panel terminals labelled “Probe” as indicated in Figure 4.

2.5.2 Averaging (optional)

Four temperature probes are required if temperature averaging is desired in larger rooms. Place the probes in appropriate locations to best average room temperature. Refer to Figure 5.

2.5.3 Humidity Probe (optional)

Install one humidity probe in an area that best reflects the overall room humidity. Connect the humidity probe to the control panel terminals labeled “Probe” as indicated in Figure 4.

2.6 ALARM

The ECS-2M provides a normally open and normally closed dry contact for alarming low or high temperature conditions. In addition, this same contact can be used to signal a power failure. This contact may be connected to an alarm system, or directly to a siren and/or auto-dialer.

Make normally open or normally closed connections as indicated in Figure 4


Momentary power interruptions may trigger false alarms! To avoid false alarming when the ECS-2M is connected to an alarm system, install a time delay relay between the ECS-2M and the alarm system.

Set Selector knob to position (12).

Following the LED display test, the unit displays the actual temperature of the room.

If temperature is not displayed, refer to the Troubleshooting section in the appendix of this document.

Fig. 1
One Fan (115V) and One Heating Unit (115V)



CHAPTER 2 - INSTALLATION

Fig. 2
Two Fans (230V)






Fig. 3
One Fan (230V) and One Heating Unit (115V)



Notes for Figures 1, 2 and 3

- ⚠️ 1 Power cut and protection devices in case of overload.
- ⚠️ 2 Only use fans that have thermal protection devices.
- ⚠️ 3 Terminals 4 and 5 are internally connected.
- ⚠️ 4 Connect the grounding wire to the ground terminal 7.
- ⚠️ 5 Should be on a different circuit from the ECS.

Fig. 4.
Probes and Alarm Wiring



CHAPTER 2 - INSTALLATION

Fig. 5
Temperature Averaging Probe Connection





Fig. 6
Main Board: Terminal Blocks, Switches, Fuses and Ground



VARIFAN RECOMMENDED CONTROL BACKUP

WARNING AND PRECAUTIONS

Equipment failure, blown fuses and/or tripped breakers may prove harmful to the content of the building. It is therefore strongly recommended to install backup devices and alarm or warning devices (see fig. 7).


BACKUP THERMOSTAT. If the Varifan control fails, then the thermostat will start the dedicated fan at full speed when the temperature will reach the T15-WD set value. Therefore, the T15-WD should be accessible for adjustment and should be set at the same temperature as the alarm, i.e. approximately 5°F above the fan relative set point.

BACKUP POWER SOURCE. The DPDT relay connects to source 1 in normal operation but will switch to source 2 if source 1 is off. The relay shall be chosen to support the load connect to it.

ALARM CIRCUIT. In regular circumstances, the alarm circuit of the Varifan Control is a short circuit. But if the Varifan control is defective or if there is no power applied to it, then the alarm circuit of the control will be an open circuit.

CHAPTER 2 - INSTALLATION

Fig 7.
Recommended control backup



3.0 USER' GUIDE

The ECS-2M front panel shown next features a LED status window and two control dials which are respectively used to select a function and adjust a setting.


LED STATUS WINDOW

The LED status window features a 3 digit LED readout for the display of temperature in Fahrenheit or Celsius, humidity level, and programmable settings.

In addition, the LED status window displays the operational status of Fans 1, and Fan 2 or a heater via three additional LEDS (shown above in LED window). When illuminated, each LED indicates that its associated fan or heater is operating. The rightmost LED lights to indicate a low or high temperature alarm condition.

CONTROL DIALS

The center dial is the Selector dial and is used to select one of the control panel's 9 primary or 9 secondary functions. The dial located to the right of the Selector dial is the Adjustor dial and is used to enter secondary function mode and to adjust the setting of each function.



ECS 2M

The 9 primary functions are:

- 1 Main set point temperature
- 2 Fan 1 modulation band
- 3 Fan 1 minimum speed
- 4 Fan 1 duty cycle timer
- 8 Fan 2/Heater relative temperature set point
- 9 Reduction per day
- 10 Record low temperature display
- 11 Record high temperature display
- 12 Room temperature display

Any one of these functions is selected by rotating the Selector dial to the corresponding number printed on the faceplate of the panel. When primary functions 1 through 4 and 8 through 11 are selected, the LED status window displays a blinking value. Function 12 displays room temperature.

The 9 secondary functions are:

- 1 Relative humidity set point
- 2 Fan 1 motor compatibility
- 3 Fan 1 minimum speed setting for humidity
- 4 Fan 1 (period) maximum speed
- 8 Fan 2/Heater differential
- 9 Minimum ramping
- 10 Low temperature alarm
- 11 High temperature alarm
- 12 Relative humidity display

Select any one of these secondary mode functions by:

- Rotating the Selector dial to (12)
- Rapidly rotating the Adjustor dial back and forth to enter secondary mode.
- Rotating the Selector dial from function (12) to any other function.

When secondary functions 1 to 4, and 8 to 11 are selected the status window displays a flashing value along with a scrolling LED display. Selection of function 12 removes the ECS from the secondary function mode.

PRIMARY FUNCTIONS

1

MAIN SET POINT

The main set point establishes the target temperature in the building. This value is used as the reference point for other settings. The main set point temperature is adjusted in 0.5 degree increments from a minimum setting of 13.5°F (-9.5°C) to a maximum setting of 105.0°F (41.0°C).

Adjusting the main set point temperature:

- rotate the Selector dial to position (1),
- rotate the Adjustor dial counterclockwise to decrease the temperature setting, clockwise to increase it.

The main set point temperature is displayed on the ECS.

Note: The reduction per day feature (primary function 9) must be (OFF) to adjust the main set point.

2

FAN 1 MOD. BAND

The Fan 1 modulation band setting establishes the temperature at which Fan 1 reaches maximum speed. The value is a temperature **difference** from the main set point.

The Fan 1 modulation band is adjusted in 0.5 degree increments from a minimum setting of 2.0°F (1.0°C) to a maximum setting of 18.0°F (10.0°C).

Adjusting the Fan 1 modulation band:

- rotate the Selector dial to position (2),
- rotate the adjustment dial counterclockwise to decrease the temperature setting, clockwise to increase it.

The Fan 1 modulation band setting is displayed on the ECS.

Example: A main set point temperature of 70°F along with a Fan 1 band setting of 5°F is set. When the temperature of the room reaches 75°F, Fan 1 operates at its maximum speed.

3

FAN 1 MIN SPEED

This function sets the minimum speed of Fan 1 when room temperature is below the main set point. This value is entered as a percentage of fan maximum speed. The Fan 1 minimum speed is adjusted in 2% increments from a minimum setting of 12% to a maximum setting of 100%.

Adjusting the minimum speed of Fan 1:

- rotate the Selector dial to position (3),
- rotate the Adjustor dial counterclockwise to decrease fan speed, clockwise to increase it.

The minimum fan speed is displayed on the ECS.

NOTE: Upon start-up, Fan 1 will run at its maximum speed for 4 seconds.

This feature helps Fan 1 to reach its set speed as quickly as possible.

4

FAN 1 DUTY CYCLE

As long as the actual temperature is below the main set point, Fan 1 operates at the minimum speed set by Fan 1 Minimum Speed (primary function 3). The Fan 1 duty cycle sets the percentage of time the fan is ON versus the percentage of time the fan is OFF. The ON time is entered as a percentage of the total time which is known as the period.

The Fan 1 duty cycle is adjusted in 5% increments from a minimum setting of OFF, 5%, 10% etc., up to a maximum setting of ON corresponding to continuous operation.

The period is fixed to 3 minutes.

Adjusting the duty cycle of Fan 1:

- rotate the Selector dial to position (4),
- rotate the Adjustor dial counterclockwise to decrease the duty cycle, clockwise to increase it.

The duty cycle is displayed on the ECS.

Example: The duty cycle is set to 50%. As long as the main set point temperature of the room has not been reached, the fan operates at a minimum speed for 1½ minute and goes OFF for 1½ minute.

8

HEAT / FAN 2 REL.

The Heater/Fan 2 relative set point is the relative temperature at which Heater/Fan 2 begins to operate. This value is the temperature **difference** from the main set point.

When a heater is being controlled, the relative set point is below the main set point. When a fan is being controlled the relative set point is above the main set point.

The Heater/Fan 2 relative set point temperature is adjusted in 0.5 degree increments from a minimum setting of -9.0°F(-5.0°C) to a maximum setting of 18.0° F (10.0°C).

Adjusting the Heater/Fan 2 relative temperature:

- rotate the Selector dial to position (8),
 - rotate the Adjustor dial counterclockwise to decrease the temperature setting, clockwise to increase it.
- The relative temperature setting is displayed ECS.

Example: The main set point temperature is adjusted to 70°F. A heater is in use and the relative set point is adjusted to -5°F. When room temperature reaches 65°F the heater begins to operate.

A second fan is in use and the relative set point is adjusted to 15°F. When room temperature reaches 85° F the second fan begins to run.

9

REDUCT. PER DAY

The reduction per day function automatically reduces the main set point by the set amount every 24 hours.

The reduction setting is adjusted in 0.01 degree increments from a minimum setting of OFF, -0.01°F (-0.01°C) to a maximum setting of -0.99°F (-0.50°C)

The main set point must be greater than the limit.

Adjusting the reduction per day:

- rotate the Selector dial to position (9),
- rotate the Adjustor dial counterclockwise to decrease the ramping rate, clockwise to increase it.

The reduction setting is displayed on the ECS.

NOTE: When reduction is activated or enabled, the main set point temperature cannot be adjusted manually.

Reduction automatically goes OFF when the minimum temperature limit is reached!

Example: The main set point temperature is set to 70°F and reduction is adjusted to -0.05°F. The following day the main set point temperature drops to 69.95°F followed by 69.90°F on the next. Although the main set point real value decreases, the display will be changed after 10 days. The main set point will then be 69.5°F.



This function displays the lowest recorded temperature since the last clear.

The record low temperature is rounded to the nearest 0.5 degree from a minimum display of 13.5°F (-10.0°C) to a maximum display of 105.0°F (40.5°C). If a temperature lower than 13.5°F is recorded, Lo is displayed.

Viewing the lowest temperature recorded:

- rotate the Selector dial to position (10)

Clearing the low temperature value

- quickly rotate the Adjustor dial counterclockwise, then clockwise.

CLr will be briefly displayed on the ECS.



This function displays the highest recorded temperature since the last clear.

The record high temperature is rounded to the nearest 0.5 degree from a minimum display of 13.5°F (-10.0°C) to a maximum display of 105.0°F (40.5°C). If a temperature higher than 105.0°F is recorded, Hi is displayed.

Displaying the highest temperature recorded:

- rotate the Selector dial to position (11)

Clearing the high temperature value

- quickly rotate the Adjustor dial counterclockwise, then clockwise.

CLr will be briefly displayed on the ECS.

12

ROOM TEMP

This function displays the room temperature. The Selector dial should normally be left at this position.

The room temperature is displayed to the nearest 0.5 degree from a minimum display of 13.5°F (-10.0°C) to a maximum display of 105.0°F (41.0°C). If the temperature is lower than 41.0°F, Lo is displayed. If the temperature is higher than 105.0°F, Hi is displayed.

Viewing the room temperature:

- rotate the Selector dial to position (12)

Room temperature is displayed on the ECS.

SECONDARY FUNCTIONS

1

REL. HUMIDITY SP

If the ECS is equipped with an optional humidity sensor, this setting regulates the humidity level of the room. The humidity setting affects the operation of Fan 1 only. When the humidity level of the room exceeds the relative humidity setting, Fan 1 runs at a new minimum speed set by secondary function (3). The fan operates at this speed as long as room temperature is below the main set point.

When the temperature of the room is greater than the main set point temperature the fan speed increases until the maximum speed for the fan is reached. The humidity level is adjusted in 1% increments from a minimum setting of 30% to a maximum setting of 80%.

Adjusting the relative humidity level:

- rotate the Selector dial to position (12),
- rapidly rotate the Adjustor dial back and forth to enter secondary function mode,
- rotate the Selector dial to position (1),
- rotate the Adjustor dial counterclockwise to decrease the humidity setting, clockwise to increase it.

The humidity setting is displayed on the ECS.

2

FAN 1 MOTOR

The Fan 1 motor compatibility setting adjusts the ECS-2M outputs to the electrical characteristics of the fan motor. Eight choices are available. Choice 1 is suited for most fans. If your motor is not listed **in the compatibility table in the Appendix**, try all choices and take the one that give the best performance with your fan. Settings 2 - 8 are the optimized settings for fan models listed in the compatibility table. Using the compatibility table, find the model number of your fan motor and take note of the fan motor compatibility number.

Setting the Fan 1 motor compatibility:

- rotate the Selector dial to position (12),
- rapidly rotate the Adjustor dial back and forth to enter secondary function mode,
- rotate the Selector dial to position (2),
- rotate the Adjustor dial to select a motor curve.

The Fan 1 motor compatibility setting is displayed on ECS.

3

FAN 1 MIN. HUM.

This function establishes the minimum speed of Fan 1 when the relative humidity level of the room exceeds the relative humidity setting. The speed setting for humidity must be configured higher than the speed setting for temperature. This value is entered as a percentage of maximum speed.

The Fan 1 minimum speed is adjusted in 2% increments from a minimum setting of 12% to a maximum setting of 100%.

Adjusting Fan 1 minimum speed for humidity:

- rotate the Selector dial to position (12),
- rapidly rotate the Adjustor dial back and forth to enter secondary function mode,
- rotate the Selector dial to position (3),
- rotate the Adjustor dial counterclockwise to decrease the speed, clockwise to increase it.

The fan 1 minimum speed setting for humidity is displayed on the ECS.

Example: The relative humidity setting is adjusted to 65%, Fan 1 minimum speed to 25%, and Fan 1 minimum speed for humidity to 50%.

When the humidity level of the room reaches 65% the minimum speed of Fan 1 gradually increases to reaches 50% when the humidity level of the room is 75%..

4

FAN 1 PERIOD

This function sets the maximum speed of Fan 1 when room temperature is higher the main set point. This value is entered as a percentage of maximum speed. Fan 1 maximum speed is adjusted in 2% increments from a minimum of 60% to a maximum of 100%.

Adjusting the maximum speed of Fan 1:

- rotate the Selector dial to position (12),
- rapidly rotate the Adjustor dial back and forth to enter secondary function mode,
- rotate the Selector dial to position (4),
- rotate the Adjustor dial counterclockwise to decrease the maximum speed, clockwise to increase it.

The Fan 1 period is displayed on the ECS.

8

HEAT/FAN 2 DIFF.

In order to minimize erratic behavior of Heater/Fan 2 when room temperature is exactly at the relative set point, the differential setting separates this ON/OFF threshold into two: one ON threshold and one OFF. This feature greatly reduces equipment wear.

The temperature difference between the two thresholds is the differential.

The differential is adjusted in 0.5 degree increments from a minimum setting of 1°F (0.5°C) to a maximum setting of 6°F (3°C) degrees.

Adjusting the differential setting:

- rotate the Selector dial to position (12),
- rapidly rotate the Adjustor dial back and forth to enter secondary function mode,
- rotate the Selector dial to position (8),
- rotate the Adjustor dial counterclockwise to decrease the differential setting, clockwise to increase it.

•

The differential is displayed on the ECS.

9

MINIMUM RAMPING

Minimum ramping is the lowest value that the ramping function can adjust the main set point to. This is a security feature.

The minimum ramping setting is adjusted in 0.5 degree increments from a minimum setting of 13.5°F (-9.5°C) to a maximum setting of 105.0°F (41.0°C).

Adjusting the minimum ramping setting:

- rotate the Selector dial to position (12),
- rapidly rotate the Adjustor dial back and forth to enter secondary function mode,
- rotate the Selector dial to position (9),
- rotate the Adjustor dial counterclockwise to decrease the minimum ramping setting, clockwise to increase it.

The minimum ramping setting is displayed on the ECS.

NOTE: When the main set point temperature reaches the minimum ramping limit, the reduction per day setting (primary function 9) automatically shuts off.

10

LO TEMP. ALARM

This function establishes the temperature **difference** below the main set point that the room can reach before a low temperature alarm is signalled. When a low temperature alarm occurs, an alarm contact is activated and the alarm LED lights up on the front panel.

The low temperature alarm is adjusted in 0.5 degree increments from a minimum setting of -32.0°F (-18.0°C) to a maximum setting of 0.0°F (0.0°C)

Adjusting the low temperature alarm setting:

- rotate the Selector dial to position (12),
- rapidly rotate the Adjustor dial back and forth to enter secondary function mode,
- rotate the Selector dial to position (10),
- rotate the Adjustor dial counterclockwise to decrease the setting, clockwise to increase it.

The low temperature alarm setting is displayed on the ECS.

11

HI TEMP ALARM

This function establishes the temperature **difference** above the main set point that the room can reach before a high temperature alarm is signalled. When a high temperature alarm occurs an alarm contact is activated and the alarm LED lights up on the front panel.

The high temperature alarm is adjusted in 0.5 degree increments from a minimum setting of 0°F (0°C) to a maximum setting of 32.0°F (18.0°C)

Adjusting the high temperature alarm:

- rotate the Selector dial to position (12),
- rapidly rotate the Adjustor dial back and forth to enter secondary function mode,
- rotate the Selector dial to position (11),
- rotate the Adjustor dial counterclockwise to decrease the setting, clockwise to increase it.

The high temperature alarm setting is displayed on the ECS.

12

RELATIVE HUMIDITY

This function displays the relative humidity of the room.

Relative humidity is displayed in 1% increments from a minimum display of 30% to a maximum display of 90%. If a humidity level lower than 30% is monitored, F2 is displayed. On the other hand, if a humidity level higher than 90% is monitored, Hi is displayed.

Displaying the relative humidity level:

- rotate the Selector dial to position (12),
- rapidly rotate the Adjustor dial back and forth to enter secondary function mode.

The humidity level is displayed on the ECS.

APPENDIX

APPENDIX

MOTOR COMPATIBILITY

CURVE	BRAND	MODEL	VOLT	SIZE
1	Multifan	4E40	230 v.	16"
2	Multifan	2E20	230	8"
2	Multifan	4E35	230 v	14"
2	Multifan	4E40	115 v.	16"
2	Multifan	4E40	230 v.	16"
2	Multifan	4E45	115 v.	18"
2	Multifan	4E45	230 v	18"
2	Multifan	4E50	115 v.	20"
2	Multifan	4E50	230 v.	20"
2	Multifan	AF24M'E	230 v.	24"
2	Multifan	6E63	230 v.	24"
2	Multifan	6E71	230 v.	28"
2	Multifan	8E92	230 v.	36"
2	Ziehl		115-230	
3	Multifan	2E30	230 v.	12"
3	Multifan	4E30	115 v.	12"
3	Multifan	4E45	230 v.	18"
3	Multifan	6E56	230 v	22"
3	Multifan/AF	AF36M	230 v.	36"
3	Leeson 1/2H	PAF20L	115 v.	20"
3	Leeson 1/2HP	AF24L	115 v.	24"
3	Aerotech-F	AT242	230 v.	24"
4	Multifan	2E25	230 v.	10"
4	Leeson 1/4HP	AF14L	115 v.	14"
4	Leeson 1/4HP	AF16L	115 v.	16"
4	Marathon 1/4HP		230 v.	16"
4	Marathon 1/3HP		230 v.	18"
4	Leeson 1/3HP	AF18L	115 v.	18"
5	GE Motor	5KCP39...	230 v.	12"
5	Leeson 1/4HP	AF12L	230 v.	12"
5	GE Motor	5KCP39...	230 v.	14"
5	Emerson	K55HXJ...	230 v.	14"
6	Oversized motors			
7	Multifan	4E30	230 v.	12"
7	Multifan	2E35	230 v.	14"
8	Multifan	4E25	230 v.	10"

TROUBLESHOOTING

SYMPTOM	CAUSE and REMEDY
Lo is continually displayed	<ul style="list-style-type: none">– Temperature is below minimum (13.5°F or -10.0°C).
Hi is continually displayed	<ul style="list-style-type: none">– Temperature is above maximum (105.0°F or 41°C).– Probe is short circuited.
Fan(s) or heater are not operating	<ul style="list-style-type: none">– Verify whether the fan's LED is on. If LED is on and fan or heater is not operating, check wiring, fan and fuse. Refer to Figure 6 for fuse location. If fuse is blown, replace with fuse of same type.
Stage 2 Fan or Heater is operating erratically	<ul style="list-style-type: none">– Verify that the software setting switch located behind the faceplate is properly set.– Verify the minimum rating (10mA at 230V or 20mA at 230V).
Display is blank	<ul style="list-style-type: none">– Verify that the line voltage selector switch is properly set.– Verify that the 10 pin flat cable between the main board and the faceplate board is connected.
F2 displayed for relative humidity	<ul style="list-style-type: none">– Humidity is below minimum (30%).– Probe is disconnected or defective.

SPECIFICATION

DESCRIPTION	VALUE
INPUT POWER	<ul style="list-style-type: none">– 12 AMPs– 115/230 -20%, +10% VAC– 50 / 60 Hz
STAGE 1 (variable speed)	<ul style="list-style-type: none">– 10 AMP; inductive 115V / 230V– Fuse 15A
STAGE 2 (dry relay contact) Not Fused	<ul style="list-style-type: none">– 10 AMP ; 115V/230V– 1/2 HP @ 115V– 1 HP @ 230V– Min. Rating 10mA at 115V*– 20mA at 230V*
ALARM (dry relay contact)	<ul style="list-style-type: none">– 2 AMP; 30V AC/DC

* Relay will not function properly if load is smaller than the minimum value.

RECORD FORM

Dial	Option	Default setting		User setting
1	Main Set Point Temperature	77°F	25°C	
2	Fan 1 Modulation Band	4°F	2°C	
3	Fan 1 Min Speed	24%	24%	
4	Fan 1 Duty Cycle Timer	ON	ON	
8	Heater/Fan 3 Relative Temp.	-3°F	-1°C	
9	Reduction per day	OFF	OFF	

2nd Function

1	Relative Humidity Set Point	65%	65%	
2	Fan 1 Motor Compatibility	2	2	
3	Fan 1 Min Speed For Humidity	50%	50%	
4	Fan 1 Period	100%	100%	
8	Heat/Fan 2 Differential	2°F	1°C	
9	Minimum Ramping Limit	65°F	18°C	
10	Lo Temperature Limit	-9°F	-5°C	
11	High Temperature Alarm	20°F	12°C	

WARRANTY

LIMITED WARRANTY

The manufactured equipment and supplied components have undergone rigorous inspection to assure optimal quality and reliability of product. Individual controls are factory tested under load, however the possibility of equipment failure and/or malfunction may still exist.

For service, contact your local distributor or supplier. The warranty period shall be for two years from manufacturing date. Proof of purchase is required for warranty validation.

In all cases, the warranty shall apply only to defects in workmanship and specifically exclude any damage caused by over-voltage, short circuit, misuse, acts of vandalism, fortuitous events, acts of God, flood, fire, hail, lightning or any other natural disaster. This warranty becomes invalid if the installation has been conducted contrary to our instructions.

The manufacturer is only responsible for the obligations set forth herein, excluding all other warranties or obligations. This warranty stipulates that in all cases the manufacturer shall be liable only for the supply of replacement parts or goods, and shall not be liable for any personal injury, damages, loss of profits, interrupted operations, fine contravention of the law or damages to the production of the PURCHASER and the PURCHASER shall take up the defense and hold the manufacturer faultless regarding any legal or extra legal proceedings, notice, or claim by the customer or by a third party, and regarding any legal and extra-legal expenses and fees brought forward by such damages.

MAV ECS-2M Ver: 1.0
June 5, 2001